

# Lead and Copper Consumer Notice Drinking Water Sample Results Table

(Safe Drinking Water Act, 1976 PA 399, as amended)

The table below lists the most recent drinking water quality Lead and Copper sample results. Lead and Copper samples are collected where cold water is typically drawn for consumption, such as drinking fountains, kitchen and classroom sinks, and break room faucets. Each facility has an established sample siting plan to identify approved sample points, in addition to a predetermined monitoring frequency.

Water System Name : GATES ELEM SCHOOL

WSSN : 2044525

<u>Sample Number</u>	<u>Sample Location</u>		<u>Sample Date</u>	<u>Analyte Code</u>	<u>Results *</u> <small>milligrams / liter</small>	<u>Comment</u>
<u>Samples related to Source #</u>		<u>001</u>				
WT122547-01	Drinking Fountain	Room 9	6/14/2019	Lead	0	
WT122547-01	Drinking Fountain	Room 9	6/14/2019	Copper	0.015	
WT122547-02	Drinking Fountain	Room 10	6/14/2019	Lead	0	
WT122547-02	Drinking Fountain	Room 10	6/14/2019	Copper	0.02	
WT122547-03	Drinking Fountain	East Hall	6/14/2019	Lead	0	
WT122547-03	Drinking Fountain	East Hall	6/14/2019	Copper	0.14	
WT122547-04	Drinking Fountain	East Hall H	6/14/2019	Lead	0	
WT122547-04	Drinking Fountain	East Hall H	6/14/2019	Copper	0.091	
WT122547-05	Drinking Fountain	Room 11	6/14/2019	Lead	0.012	
WT122547-05	Drinking Fountain	Room 11	6/14/2019	Copper	0.012	
WT122547-06	Drinking Fountain	Room 12	6/14/2019	Lead	0	
WT122547-06	Drinking Fountain	Room 12	6/14/2019	Copper	0.013	
WT122547-07	Drinking Fountain	Room 13	6/14/2019	Lead	0	
WT122547-07	Drinking Fountain	Room 13	6/14/2019	Copper	0.014	
WT122547-08	Kitchen Sink	3 Compartment Sin	6/14/2019	Lead	0	
WT122547-08	Kitchen Sink	3 Compartment Sin	6/14/2019	Copper	0.026	
WT122547-09	Drinking Fountain	Room 14	6/14/2019	Lead	0	
WT122547-09	Drinking Fountain	Room 14	6/14/2019	Copper	0.02	
WT122547-10	Drinking Fountain	Room 16	6/14/2019	Lead	0	
WT122547-10	Drinking Fountain	Room 16	6/14/2019	Copper	0.024	
WT122547-11	Drinking Fountain	Room 17	6/14/2019	Lead	0	
WT122547-11	Drinking Fountain	Room 17	6/14/2019	Copper	0.023	
WT122547-12	Downstream of Pos	Room 18	6/14/2019	Lead	0	
WT122547-12	Downstream of Pos	Room 18	6/14/2019	Copper	0.025	
WT122547-13	Drinking Fountain	Room 19	6/14/2019	Lead	0	

**\* All Lead and Copper sample results will be reviewed by your local health department to assess compliance with Lead and Copper regulations under the Safe Drinking Water Act, 1976 PA 399, as amended, the U.S. Environmental Protection Agency (U.S. EPA). Results that are below the detection limit of the analytical method employed by the laboratory are listed as zero.**

For information on the health effects of Lead/Copper, and how to decrease your exposure, call the Safe Drinking Water Information Hotline at +1 (800)-426-4791, visit the U.S. EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), or contact your health care provider.

# Lead and Copper Consumer Notice Drinking Water Sample Results Table

(Safe Drinking Water Act, 1976 PA 399, as amended)

The table below lists the most recent drinking water quality Lead and Copper sample results. Lead and Copper samples are collected where cold water is typically drawn for consumption, such as drinking fountains, kitchen and classroom sinks, and break room faucets. Each facility has an established sample siting plan to identify approved sample points, in addition to a predetermined monitoring frequency.

continuing Page 2  
Water System Name: **GATES ELEM SCHOOL**

WSSN: **2044525**

<u>Sample Number</u>	<u>Sample Location</u>		<u>Sample Date</u>	<u>Analyte Code</u>	<u>Results *</u> <small>milligrams / liter</small>	<u>Comment</u>
WT122547-13	Drinking Fountain	Room 19	6/14/2019	Copper	0.018	
WT122547-14	Drinking Fountain	Room 20	6/14/2019	Lead	0	
WT122547-14	Drinking Fountain	Room 20	6/14/2019	Copper	0.023	
WT122547-15	Drinking Fountain	Room 21	6/14/2019	Lead	0	
WT122547-15	Drinking Fountain	Room 21	6/14/2019	Copper	0.017	
WT122547-16	Drinking Fountain	Room 22	6/14/2019	Lead	0	
WT122547-16	Drinking Fountain	Room 22	6/14/2019	Copper	0.077	
WT122547-17	Drinking Fountain	Room 23	6/14/2019	Lead	0	
WT122547-17	Drinking Fountain	Room 23	6/14/2019	Copper	0.032	
WT122547-18	Drinking Fountain	Room 24	6/14/2019	Lead	0	
WT122547-18	Drinking Fountain	Room 24	6/14/2019	Copper	0.036	
WT122547-19	Drinking Fountain	Room 25	6/14/2019	Lead	0	
WT122547-19	Drinking Fountain	Room 25	6/14/2019	Copper	0.022	
WT122547-20	Drinking Fountain	Room 26	6/14/2019	Lead	0	
WT122547-20	Drinking Fountain	Room 26	6/14/2019	Copper	0.024	
WT122547-21	Break Room Sink	Teacher's Lounge	6/14/2019	Lead	0.003	
WT122547-21	Break Room Sink	Teacher's Lounge	6/14/2019	Copper	0.065	
WT122547-22	Drinking Fountain	Lobby	6/14/2019	Lead	0	
WT122547-22	Drinking Fountain	Lobby	6/14/2019	Copper	0.12	
WT122547-23	Drinking Fountain		6/14/2019	Lead	0	
WT122547-23	Drinking Fountain		6/14/2019	Copper	0.11	
WT122547-24	Drinking Fountain	South Hall 11C	6/14/2019	Lead	0	
WT122547-24	Drinking Fountain	South Hall 11C	6/14/2019	Copper	0.13	
WT122547-25	Drinking Fountain	South Hall	6/14/2019	Lead	0	
WT122547-25	Drinking Fountain	South Hall	6/14/2019	Copper	0.095	

**\* All Lead and Copper sample results will be reviewed by your local health department to assess compliance with Lead and Copper regulations under the Safe Drinking Water Act, 1976 PA 399, as amended, the U.S. Environmental Protection Agency (U.S. EPA). Results that are below the detection limit of the analytical method employed by the laboratory are listed as zero.**

For information on the health effects of Lead/Copper, and how to decrease your exposure, call the Safe Drinking Water Information Hotline at +1 (800)-426-4791, visit the U.S. EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), or contact your health care provider.

# Lead and Copper Consumer Notice Drinking Water Sample Results Table

(Safe Drinking Water Act, 1976 PA 399, as amended)

The table below lists the most recent drinking water quality Lead and Copper sample results. Lead and Copper samples are collected where cold water is typically drawn for consumption, such as drinking fountains, kitchen and classroom sinks, and break room faucets. Each facility has an established sample siting plan to identify approved sample points, in addition to a predetermined monitoring frequency.

continuing, Page 3  
Water System Name: **GATES ELEM SCHOOL**

WSSN : 2044525

<u>Sample Number</u>	<u>Sample Location</u>		<u>Sample Date</u>	<u>Analyte Code</u>	<u>Results *</u> milligrams / liter	<u>Comment</u>
WT122547-26	Drinking Fountain	Room 2	6/14/2019	Lead	0	
WT122547-26	Drinking Fountain	Room 2	6/14/2019	Copper	0.022	
WT122547-27	Drinking Fountain	Room 4	6/14/2019	Lead	0	
WT122547-27	Drinking Fountain	Room 4	6/14/2019	Copper	0.019	
WT122547-28	Drinking Fountain	Room 5	6/14/2019	Lead	0	
WT122547-28	Drinking Fountain	Room 5	6/14/2019	Copper	0.017	
WT122547-29	Drinking Fountain	Room 6	6/14/2019	Lead	0	
WT122547-29	Drinking Fountain	Room 6	6/14/2019	Copper	0.026	
WT122547-30	Drinking Fountain	Room 7	6/14/2019	Lead	0	
WT122547-30	Drinking Fountain	Room 7	6/14/2019	Copper	0.013	
WT122547-31	Drinking Fountain	Room 8	6/14/2019	Lead	0	
WT122547-31	Drinking Fountain	Room 8	6/14/2019	Copper	0.016	

**\* All Lead and Copper sample results will be reviewed by your local health department to assess compliance with Lead and Copper regulations under the Safe Drinking Water Act, 1976 PA 399, as amended, the U.S. Environmental Protection Agency (U.S. EPA). Results that are below the detection limit of the analytical method employed by the laboratory are listed as zero.**

For information on the health effects of Lead/Copper, and how to decrease your exposure, call the Safe Drinking Water Information Hotline at +1 (800)-426-4791, visit the U.S. EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), or contact your health care provider.

Printed: 9/11/2019